Bureau of Facility Standards ASPEN: Tag Summary Report (TAG1) from 01/01/2012 thru 12/31/2012

FED - K - LSC 2000 - Long Term Care

Tag		Cite Frequency	Rank
K 147	Electrical Wiring	37	1
K 062	Sprinkler System Maintenance	33	2
K 144	Generator Testing	25	3
K 029	Hazardous Area Protection	24	4
K 038	Exit Access	22	5
K 056	Sprinkler Installation	19	6
K 018	Corridor Doors	18	7
K 069	Cooking Facilities	17	8
K 050	Fire Drills	15	9
K 027	Smoke Barrier Doors	9	10

TagSummary.rpt

Cite Frequency column counts the first citation of a tag - uncorrected citations of the same tag on revisits are not recounted.

Citations with empty scope and severity are included in counts but not averages.

Printed 02/19/2013

The language used in the Tag reflects the main category, however, within each tag there may be multiple components cited within that single main category.

Tags cited by more than one surveyor on the same survey are counted once.